

2022 Top-10 Violations

1.	Extension cords and flexible cords shall not be a substitute for permanent wiring	6.	Working Space and Clearance. A working space of not less than 30 inches in width, 36 inches in depth, and 78 inches in height shall be provided in front of electrical service equipment.
2.	Group R-2 dormitories. Candles, incense and similar open-flame-producing items shall not be allowed in sleeping units in Group R-2 dormitory occupancies.	7.	Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible building official. Electrical wiring, devices, appliances
3.	Door operation. Swinging fire doors shall close from the full-open position and latch automatically	8.	Obstructions. A means of egress shall be free from obstructions that would prevent its use, including the accumulation of snow and ice.
4.	Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes	9.	Relocatable power taps shall be directly connected to a permanently installed receptacle
5.	Reliability. Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency where the building area served by the means of egress	10.	Combustible decorative materials. In other than Group I-3, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section FC807.4